

CERTIFICATE OF SUITABILITY FOR APPLICATION

Nr. 20606470

**Dynameco Aerosol fire extinguishers
Dynamit Nobel Defence GmbH
used in
fire detection- and extinguishing system TMZ 6-A**

***Fa. Egon Harig GmbH
Gewerbering 4
22113 Oststeinbek***

With regard to the design described in the below mentioned expert's opinion this confirmation of suitability for application certifies that the Dynameco Aerosol-extinguishing generator used for fire detection- and extinguishing system TMZ 6-A of Egon Harig GmbH is able to extinguish fires in tool machines with closed workrooms in case of use of non water-soluble cooling lubricants and non-combustible work materials during the phase when these fires emerge.

This certificate of suitability for application is only valid in connection with the expert's opinion 20606470 GS-FS-Hoi/Ze/Lot, issued by DMT GmbH & Co. KG – Expert Body for Fire Protection.

Dortmund, 1st September 2009

**DMT GmbH & Co. KG
Expert Body for Fire Protection**



Hoischen



Lottermann

